

DECLARATION OF CONFORMITY

No. S.CE/EN/0644/V2/2015/562

**KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

herewith declares that the product:

RESIDUAL-CURRENT CIRCUIT BREAKER WITH OVERLOAD PROTECTION

Type / types: **KRO6-2/B6/30, KRO6-2/B10/30, KRO6-2/B16/30,
KRO6-2/B20/30, KRO6-2/B25/30, KRO6-2/B10/30-A,
KRO6-2/B16/30-A, KRO6-2/C10/30, KRO6-2/C16/30,
KRO6-2/C10/30-A, KRO6-2/C16/30-A**

Trade mark:



Basic parameters: $U_c = 230V\sim$; $I_n = 6A, 10A, 16A, 20A, 25A$; $I_{\Delta n} = 30mA$; $I_{nc} = 6000A$;
B-, C- type; Energy limiting class - 3

is in conformity with the provisions of the following EC directive(s)
(including all applicable amendments):

Directive (LVD) – 2006/95/EC**Directive (RoHS) – 2011/65/EC**

references of standards and/or technical specifications applied for this declaration of conformity:

EN 61009-1:2012 +A1:2014 +A2:2014**EN 50581:2012****Additional information:**

Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.

Last two digits of the year in which the **CE** marking was affixed: **15**

NWP/5702, NWP/5703; ID 0644; S.CE/562**Radzionków, 17.11.2015**

Kanlux S.A. Kierownik Laboratorium Badawczego
Kanlux S.A. Dyrektor, Działu Technicznego
Kanlux S.A. Specjalista ds. Wdrożenia i Certyfikacji Produktów

Krzysztof Żurek
Dariusz Staniczek
Adam Wabnic

name and function of the signatory

www.kanlux.pl**Kanlux SA**

ul. Objazdowa 1-3, 41-922 Radzionków, Polska
tel. /32/388 74 00, fax /32/388 74 99, e-mail: kanlux@kanlux.pl

Nr KRS 0000286139 • Sąd Rejonowy w Gliwicach, X Wydział Gospodarczy KRS
NIP: 645-243-27-93 • REGON: 240672104
Kapitał zakładowy: 35 500 000 zł opłacony w całości
ING BANK SŁĄSKI O/BYTOM: 82 1050 1230 1000 0022 5379 7878