

**UE DECLARATION OF CONFORMITY**

No CE/EN/0731/V2/2020/649

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

TERMINAL BLOCKType/types: (1) **KTB-125-1-M**, (2) **KTB-125-7-M**, (3) **KTB-125-15-M**Trade mark: **IDEAL^{TS}**
by KanluxBasic parameters: (1) – U_i: 690V~; 50/60Hz; I_n: 125A (40°C); I_{pk}: 20kA; 2P; IP00
(2) – U_i: 500V~; 50/60Hz; I_n: 125A (40°C); I_{pk}: 20kA; 4P; IP00
(3) – U_i: 500V~; 50/60Hz; I_n: 125A (40°C); I_{pk}: 20kA; 8P; IP00

Batch or serial number: #F12

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU**Directive (RoHS) – 2011/65/EU, (EU)2015/863**

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60947-7-1:2009**EN 50581:2012****Additional information:**Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.**NWP/9984, NWP/9985, NWP/9986; ID 0731; S.CE/649****Radzionków, 01.10.2020**

Kanlux S.A. Kierownik Laboratorium Badawczego	Kanlux S.A. Dyrektor Działu Technicznego	Kanlux SA Kierownik ds. Wdrożeń i Certyfikacji Produktów
Krzysztof Żurek	Dariusz Staniczek	Adam Wabnic
.....		
(name, function) (signature)		

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | **kanlux.com**