

EU DECLARATION OF CONFORMITY

No CE/EN/0643/V4/2023/0561

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

RESIDUAL-CURRENT CIRCUIT BREAKERType/types: **KRD6-2/25/30, KRD6-2/40/30, KRD6-2/63/30, KRD6-4/25/30, KRD6-4/40/30, KRD6-4/63/30, KRD6-2/16/10, KRD6-2/25/30-A, KRD6-2/40/30-A, KRD6-4/25/30-A, KRD6-4/40/30-A, KRD6-4/63/30-A, KRD6-2/16/10-A, KRD6-2/25/300, KRD6-4/100/30, KRD6-4/100/30-A, KRD6-4/63/300**

Trade mark:

IDEAL^{TS}
by Kanlux

Basic parameters:

Uc = 230V~ (1P+N), 400V~ (3P+N); In = 16A, 25A, 40A, 63A, 100A;
IΔn = 10mA, 30mA, 300mA; Inc = 6000A; Im = 500A

Batch or serial number:

#CB4

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU**Directive (RoHS) – 2011/65/EU, (EU)2015/863**

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 61008-1:2012 +A1:2014 +A2:2014 +A11:2015**EN 61008-2-1:1994 +A11:1998****EN IEC 63000:2018**

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.**NWP/5698, NWP/5699, NWP/5700, NWP/5701; ID 0643; S.CE/0561****Radzionków, 04.07.2023**

Kanlux S.A. Kierownik Laboratorium Badawczego
Kanlux S.A. Dyrektor Działu Technicznego
Kanlux S.A. Kierownik ds. Wdrożeń i Certyfikacji Produktów

Krzysztof Żurek
Dariusz Staniczek
Adam Wałnic

(name, function) (signature)

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | kanlux.com