



UE DECLARATION OF CONFORMITY

No CE/EN/0644/V4/2022/0562

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

RESIDUAL-CURRENT CIRCUIT BREAKER WITH OVERLOAD PROTECTION

Type/types:

**KRO6-2/B6/30, KRO6-2/B10/30, KRO6-2/B16/30,
KRO6-2/B20/30, KRO6-2/B25/30, KRO6-2/B10/30-A,
KRO6-2/B16/30-A, KRO6-2/C10/30, KRO6-2/C16/30,
KRO6-2/C10/30-A, KRO6-2/C16/30-A, KRO6-2/C25/30,
KRO6-2/C25/30-A, KRO6-2/C32/30, KRO6-2/C32/30-A**

Trade mark:

IDEAL^{TS}

by Kanlux

Basic parameters:

Uc = 230V~; In = 6A, 10A, 16A, 20A, 25A, 32A; IΔn = 30mA; Inc = 6000A;
B-, C- type; Energy limiting class - 3

Batch or serial number:

#DK2

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU**Directive (RoHS) – 2011/65/EU, (EU)2015/863**

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 61009-1:2012 +A1:2014 +A2:2014 +A11:2015 +A12:2016 +A13:2021**EN IEC 63000:2018**

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.**NWP/5702, NWP/5703; ID 0644; S.CE/0562****Radzionków, 08.12.2022****Kanlux S.A.**
Dyrektor Działu Technicznego
*Dariusz Staniczek***Kanlux S.A.**
Kierownik Laboratorium Badawczego
*Krzysztof Żurek***Kanlux SA**
Kierownik ds. Wdrożeń
i Certyfikacji Produktów
Adam Wabnicki

(name, function) (signature)

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | kanlux.com