



EU DECLARATION OF CONFORMITY

No CE/EN/1379/V1/2024/1220

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

RESIDUAL-CURRENT CIRCUIT BREAKER WITH OVERLOAD PROTECTION

Type/types:

**KRO10-2/B6/30, KRO10-2/B10/30, KRO10-2/B10/30-A,
KRO10-2/B16/30, KRO10-2/B16/30-A, KRO10-2/B20/30,
KRO10-2/B20/30-A, KRO10-2/B25/30, KRO10-2/C10/30,
KRO10-2/C10/30-A, KRO10-2/C16/30, KRO10-2/C16/30-A,
KRO10-2/C20/30, KRO10-2/C20/30-A, KRO10-2/C25/30,
KRO10-2/C25/30-A, KRO10-2/C32/30, KRO10-2/C32/30-A**

Trade mark:

IDEAL^{TS}
by **Kanlux**

Basic parameters:

Uc = 230V~; In = 6A, 10A, 16A, 20A, 25A, 32A; IΔn = 30mA; Inc = 10000A;
B-, C- type; Energy limiting class - 3

Batch or serial number:

#AK1

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU

Directive (RoHS) – 2011/65/EU, (EU)2015/863

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 61009-1:2012 +A1:2014 +A2:2014 +A11:2015 +A12:2016 +A13:2021

EN IEC 63000:2018

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.

NWP/WO; ID 1377; S.CE/1220

Radzionków, 20.11.2025

Kanlux S.A. Kierownik Laboratorium Badawczego
Krzysztof Żurek
Kanlux S.A. Dyrektor Działu Technicznego
Dariusz Staniczek
Kanlux SA Kierownik ds. Wdrożeń i Certyfikacji Produktów
Adam Wabnicki
(name, function) (signature)

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | **kanlux.com**