

# Kanlux

## Kanlux FOGLER E

PIR  
MOTION  
sensor

HIGH  
lumen



|                   |               |            |               |                    |                         |          |
|-------------------|---------------|------------|---------------|--------------------|-------------------------|----------|
| [V]<br>220-240 AC | [Hz]<br>50    | [°]<br>120 | [h]<br>≥20000 | [h]<br>25000       | ellipse<br>≤ 6x MacAdam | Ra<br>80 |
| Hg                | SMD           |            |               | IP<br>20           |                         |          |
|                   | [mm]<br>1-1,5 | [m]<br>6   | [°]<br>360    | [s] - [min]<br>2-2 | [lx]<br>15-2000         | 0,5m     |
|                   |               |            |               |                    |                         |          |



### FOGLER E 12W NW

|                 |              | [W] | [lm] | Tc [K] |     | SENSOR<br> |
|-----------------|--------------|-----|------|--------|-----|------------|
| FOGLER E 12W NW | <b>18122</b> | 12  | 1000 | 4000   | бял | PIR        |
| FOGLER E 17W NW | <b>18123</b> | 17  | 1100 | 4000   | бял | PIR        |
| FOGLER E 24W NW | <b>18124</b> | 24  | 1800 | 4000   | бял | PIR        |




FOGLER E 12W NW




FOGLER E 17W NW




FOGLER E 24W NW



FOGLER E 12W NW



FOGLER E 17W NW



FOGLER E 24W NW

Date of issue: 28.11.2025, 10:45

Запазва се правото за въвеждане на технически промени. Данните, съдържащи се в този материал, не са правно обвързващи.

Фотометрия: резултати, получени по време на изпитване на дадения екземпляр.

Kanlux S.A. ul. Objazdowa 1-3, 41-922 Radzionków, Poland [kanlux@kanlux.com](mailto:kanlux@kanlux.com)