


19456 SEIDY CT-DTO50-W/M

Ceiling-mounted spotlight fitting 5905339194565

















Kanlux SEIDY is a popular family of holders in which you can choose from 1 to 4 light points. You will compose ideal lighting of coffee shops, hotel interiors and privacy interiors of them.

GENERAL DATA:

Colour: matte white

Necessity of using self-shielding lamps: yes
Place of assembly: Recessed mount in the ceiling

Place of application: Indoors

Minimum distance from the illuminated object: 0,5m

The product is not suitable to be covered with a heat-insulating

material: yes Height [mm]: 26 Diameter [mm]: 92

Assembly hole [mm]: Ø80

TECHNICAL DATA:

Rated voltage [V]: 12 AC; 12 DC Maximum power [W]: max 10

Class of protection against electric shock: III

Light source: MR16 **Light source included**: no

Cap: Gx5,3

Ambient temperature range to which the product can be

exposed: 5÷25

Enclosure material: aluminum alloy Connection type: Free cable ends

Wire length [m]: 0.12 Wire diameter [mm²]: 0.75

Lighting-fixture angle regulation: in one axis **Lighting-fixture angle regulation** [°]: 30

IP class: 20

LOGISTIC DATA:

Unit of measurement: unit Packaging method: 50

Number of units in the packaging: 50

Net unit weight [g]: 102 Grammage [g]: 137

Length of a unit pack [cm]: 11 Width of a unit pack [cm]: 4.5 Height of a unit pack [cm]: 10

Weight of a cardboard box [kg]: 6.85

Date of issue: 11.05.2023, 13:59


We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.





19456 SEIDY CT-DTO50-W/M

Ceiling-mounted spotlight fitting



Width of a cardboard box [cm]: 23
Height of a cardboard box [cm]: 23
Length of a cardboard box [cm]: 57
Volume of a cardboard box [m³]: 0.030153



Date of issue: 11.05.2023, 13:59

We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.

