

29170 INVO OP EL-53-L-GR

Architectural lighting with replaceable source of light


5905339291707






















Kanlux INVO OP is a series of external architectural luminaires. The whole family is composed of posts and façade luminaires. You can use your favourite light colour in Kanlux INVO luminaires since it is adapted for replaceable sources with a E27 cap.

GENERAL DATA:

Colour: graphite

Place of assembly: wall mounted

Place of application: Indoors and outdoors

Minimum distance from the illuminated object: 0,5m

Replaceable light source: yes

Length [mm]: 170 Width [mm]: 170 Height [mm]: 435

TECHNICAL DATA:

Rated voltage [V]: 220-240 AC Rated frequency [Hz]: 50 Maximum power [W]: max 20

Class of protection against electric shock: ||

Lampshade material: plastic Light source: GLS/CFL/LED Light source included: no

Cap: E27

Ambient temperature range to which the product can be

exposed: -20÷35

Enclosure material: plastic **Connection type**: Terminal block

Range of sections of wires used [mm²]: $0.75 \div 1.5$

IP class: 54

LOGISTIC DATA:

Packaging method: 1

Number of units in the secondary packaging: 1

Number of units in the packaging: 1

Net unit weight [g]: 1720 Grammage [g]: 2360

Length of a unit pack [cm]: 26.5 Width of a unit pack [cm]: 26.5 Height of a unit pack [cm]: 53

Weight of a cardboard box [kg]: 2.36 Width of a cardboard box [cm]: 26.5 Height of a cardboard box [cm]: 53 Length of a cardboard box [cm]: 26.5

Date of issue: 16.11.2022, 04:57

We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.





29170 INVO OP EL-53-L-GR


Architectural lighting with replaceable source of light



Volume of a cardboard box [m³]: 0.037219

ADDITIONAL INFORMATION:

• Milky lampshade



We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.

