

# **35816** OS-L5D-WW-RST-W-P1

## Recessed - Mounted LED Office Fixture

5905339358165




















#### **GENERAL DATA:**

Colour: white

Place of assembly: Recessed mount in the ceiling

Place of application: Indoors

Minimum distance from the illuminated object: 0,5m

Compatible with a dimmer: no

The product is not suitable to be covered with a heat-insulating

material: yes Length [mm]: 595 Width [mm]: 595 Height [mm]: 34

Integrated LED light source: yes

### **TECHNICAL DATA:**

Rated voltage [V]: 220-240 AC Rated frequency [Hz]: 50 Maximum power [W]: 31W

Class of protection against electric shock:

Lampshade material: plastic Diode type: LED SMD

Luminous flux of the light fitting [lm]: 4300

Colour temperature: Warm white

Correlated colour temperature [K]: 3000 Colour consistency in McAdam ellipses: ≤3

Colour rendering index: 80 Service life [h]: 50000

Luminous-flux-retention factor at the end of rated service life:

L90B10

Number of on/off cycles: ≥30000

Lighting angle [°]: 50

Ambient temperature range to which the product can be

**exposed**: 5÷25 **Shade type**: louvre

Enclosure material: Metal


Connection type: Self-clamping block

Range of sections of wires used [mm<sup>2</sup>]: 1,5÷2,5

Lamp-heating time [s]: ≤1 Lamp-ignition time [s]: ≤0,5 Rodzaj soczewki [°]: 50

**IP class**: 20 **UGR**: ≤15

Date of issue: 10.07.2024, 08:55








# 35816 OS-L5D-WW-RST-W-P1

### Recessed - Mounted LED Office Fixture



## LOGISTIC DATA:

Unit of measurement: unit Packaging method: 1

Number of units in the secondary packaging: 1


Number of units in the packaging: 1


### **ADDITIONAL INFORMATION:**

• 5 years Warranty under the terms of the warranty statement, available on our website



Oprawa: KANLUX S.A. (kat 35816) OS-L5D-WW-RST-W-P1 Lampy: 4 x OS-L5D-WW-RST





We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.

