

04260 TUNA S1101-W


Ceiling-mounted light fitting with replaceable light source

5905339042606

















Kanlux TUNA ceiling light fixture is a good choice for staircases, basements, attics and other such rooms. Proper level of protection against dust and moisture allows for its use both indoors and outdoors.

GENERAL DATA:

Colour: white

Place of assembly: wall mounted, ceiling mounted

Place of application: Indoors and outdoors

Minimum distance from the illuminated object: 0,5m

Replaceable light source: yes

Height [mm]: 100 Diameter [mm]: 225

TECHNICAL DATA:

Rated voltage [V]: 220-240 AC Rated frequency [Hz]: 50 Maximum power [W]: max 25

Class of protection against electric shock: II

Lampshade material: glass
Light source: GLS/CFL/LED
Light source included: no
Cap (Light source): E27
Enclosure material: plastic
Connection type: Terminal block

Range of sections of wires used [mm²]: 1-1,5

IP class: 44

LOGISTIC DATA:

Unit of measurement: unit Packaging method: 5

Number of units in the secondary packaging: 1

Number of units in the packaging: 5

Net unit weight [g]: 1150 Grammage [g]: 1375

Gross unit weight [g]: 1123.2 Length of a unit pack [cm]: 22.5 Width of a unit pack [cm]: 11 Height of a unit pack [cm]: 23

Weight of a cardboard box [kg]: 6.875 Width of a cardboard box [cm]: 24 Height of a cardboard box [cm]: 47

Date of issue: 17.12.2024, 10:22

We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.





04260 TUNA S1101-W


Ceiling-mounted light fitting with replaceable light source




Length of a cardboard box [cm]: 45 Volume of a cardboard box [m³]: 0.05076

KANLUX S.A. (kat 4260) TUNA S1101 / Krzywa rozsyłu światła (biegunowo)

orawa: KANLUX S.A. (kat 4260) TUNA S1101





We reserve the right to make technical changes. The data contained in this material are not legally binding. Photometry: the results obtained from testing were from a specific sample.

